

**VILLAGE OF POTTER**

**ORDINANCE 2015-1**

An ordinance concerning the installation of a water softener with DIR controls.

The Village of Potter does ordain as follows:

In order to help reduce the amount of chlorides being treated at the wastewater treatment plant, the Village of Potter shall require that any new or replacement water softener installed after April 1, 2015, shall have DIR (demand initiated regeneration) controls and shall meet the "High Efficiency Softener" standards of the Water Quality Association which are 3350 grains hardness removed per one pound of salt.

This ordinance shall take effect upon passage.

Dated this \_8th\_\_\_\_ day of April, 2015.

---

Doug Lau, Village President

---

Dennis Gruett, Clerk